


**ADDENDUM 002
REQUEST FOR BIDS
(Overhead Crane Installation)
RFB # (D8PP-10038)**

Bidders shall acknowledge receipt of Addendum 002 (TWO) by signing and including it with the original bid. The due date for receipt of bids remains unchanged by this Addendum. Accordingly, the following clarifications, questions and answers are believed to be of general interest to all potential Bidders. All other terms and conditions remain unchanged and in full force.

Name and Title of Signer (Print or type)	Name and Title of Department Authority Name: Andy McNeill Title: Intermediate Procurement Agent
Bidder/Offeror Signature	Department of Transportation 
(Signature of person authorized to sign)	(Authorizing Signature)
Date Signed:	Date Signed: January 20, 2010

QUESTIONS/CLARIFICATIONS

THE BID CLOSING DATE IS NOW SCHEDULED FOR FEBRUARY 4, 2010, ON OR BEFORE 1:00 P.M., C.S.T.

Question: Can the crane support posts be placed directly in front of the exit door on the southwest corner of the building.

Answer: All supports shall be installed or fabricated in a manner as not to block or cause any obstructions to the exit door. Any design that blocks this exit route will not be considered.

Specification Modification:

It has been discovered that the two cranes that we have specified to be used are not exact duplicates of each other. One crane is longer and taller than the other crane. The bid is now changed to require only one of the two cranes to be installed. Only the crane marked with serial number # 8593 will be installed. Section 2.2.4 is amended to reflect this change:

2.2.4 Crane Specifications:

Brand: ~~DeShazo Crane Company~~

DeShazo Crane Company

Catalog# 45A00540

45A00535

Serial #'s 8149

8593

Capacity: 10,000 pounds

10,000 pounds

Customer Markings: 8596-7988

8596-7988

Date of Manufacture: June 1993

June 1993

Should you have any questions, please call me at 417-895-7645.

Thank you,



Andy McNeill, CPPB
Intermediate Procurement Agent